



NOTES:

1. THE MIN PIPE SIZE = 15" RCP, MIN LENGTH = 20'
2. A LARGER PIPE SIZE MAY BE REQUIRED IF DETERMINED BY A PROFESSIONAL ENGINEER
3. THE LENGTH OF PIPE REQUIRED SHALL BE THE AMOUNT NEEDED TO EXTEND (1') BEYOND THE TOE OF A 2:1 SLOPE. SEE SECTION DETAIL
4. DITCH SHALL BE INSPECTED BY CITY STAFF PRIOR TO PIPE INSTALLATION

NOT TO SCALE