



NOTES:

1. REDUCED PRESSURE PRINCIPLE ASSEMBLIES (RP) MUST CONFORM TO CITY OF KANNAPOLIS SPECIFICATIONS.
2. APPROVED RP INCLUDES SHUT OFF VALVES #1 AND #2 AS PART OF THE ASSEMBLY. NO SUBSTITUTIONS SHALL BE PERMITTED.
3. FIRE LINE SERVICES SHALL HAVE OUTSIDE STEM AND YOKE (OS & Y) HAND WHEEL OPERATORS.
4. 8"- 10" RP SHALL BE SUPPORTED AT CENTER WITH BRICK PEDESTAL.
5. RESTRAINED JOINTS SHALL BE WITH MEGA LUG RESTRAINTS OR APPROVED EQUAL.
6. TEST COCK #1 SHALL BE UPSTREAM OF SHUT OFF VALVE #1 AND IS PART OF THE APPROVED ASSEMBLY.
7. HOT BOX SHALL BE A 20 MIL. ORTHOTHALIC POLYESTER GELCOAT WITH ULTRA-VIOLET INHIBITORS. GELCOAT SHELL IS BACKED WITH 1/4" CHOP-STRAND POLYRESIN BONDED FIBERGLASS AND LINED WITH POLYURETHANE INSULATION (MIN. R FACTOR 8.5).
8. HEATED ENCLOSURES ARE REQUIRED FOR ALL FIRE LINE CONNECTIONS.
9. SEE CITY OF KANNAPOLIS LAND DEVELOPMENT STANDARDS MANUAL APPENDIX B FOR LIST OF APPROVED PRODUCTS.

NOT TO SCALE