



NOTES:

1. SIZES SHALL BE VERIFIED BY THE DEVELOPERS ENGINEER.
2. BACKFLOW PREVENTERS SHALL BE REDUCED PRESSURE PRINCIPLE ASSEMBLIES WHEN LINES ARE CONNECTED TO HIGH HAZARD USES IN ACCORDANCE WITH CITY OF KANNAPOLIS CROSS CONNECTION CONTROL POLICY.
3. 1-1/2" & LARGER DOMESTIC METER SHALL BE INSTALLED WITH GATE VALVE.
4. SEE CITY OF KANNAPOLIS LAND DEVELOPMENT STANDARDS MANUAL APPENDIX B FOR LIST OF APPROVED PRODUCTS.