



NOTES:

1. THE CONTRACTOR MUST INSTALL A REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTION ASSEMBLY (RP) IMMEDIATELY AFTER THE HYDRANT METER IS SET.
2. BACKFLOW ASSEMBLIES MUST BE TESTED BY A CERTIFIED TESTER PRIOR TO USE.
3. PRIOR TO USE AN INSPECTION BY THE CITY IS REQUIRED FOR ALL HYDRANT METER BACKFLOW PREVENTION ASSEMBLIES.
4. EACH TIME THE HYDRANT METER BACKFLOW PREVENTION ASSEMBLY IS RELOCATED IT MUST BE TESTED.
5. THE CONTRACTOR WILL BE BILLED TO REPLACE AND INSTALL ANY PARTS NOT RETURNED WITH HYDRANT METER.
6. HYDRANT, BACKFLOW ASSEMBLY, AND METER SHALL BE ADEQUATELY INSULATED TO PREVENT FREEZING.
7. HYDRANT WRENCH ONLY, NO PIPE WRENCH ALLOWED
8. SEE CITY OF KANNAPOLIS LAND DEVELOPMENT STANDARDS MANUAL APPENDIX B FOR LIST OF APPROVED PRODUCTS.

NOT TO SCALE