



NOTES:

1. THIS DETAIL SHALL BE USED ONLY WHERE INDICATED ON PLANS.
2. ALL EXTERIOR DROP PIPE AND FITTINGS TO BE DUCTILE IRON.
3. MEGALUG MAY BE USED AS A METHOD OF RESTRAINT IN LIEU OF 1/2" STEEL ROD ATTACHED TO FLANGE ON EACH SIDE OF STACK.
4. ALL CONNECTIONS TO PRECAST MANHOLE STRUCTURES SHALL BE WATERTIGHT.
5. PROPOSED CONNECTION TO BE USED WHERE THE DROP EXCEEDS 2'-0" FROM INVERT IN TO INVERT OUT.
6. SEE STD. S-MH-02A & B FOR STANDARD MANHOLE.

NOT TO SCALE