



**NOTES:**

1. VENT PIPE SHALL BE IN ACCORDANCE WITH WSACC SPECIFICATION SECTION 02605.
2. VENT OPENING TO POINT DOWNSTREAM.
3. TWO 3" X 3/8" STEEL STRAPS, AND 5/8" X 4" EXPANSION ANCHOR BOLTS SHALL BE USED TO SECURELY ANCHOR VENT.
4. THE FOLLOWING TABLE SHALL BE USED TO DETERMINE THE LENGTH OF THE STRAPPED LEG:

HEIGHT OF VENT PIPE	LENGTH OF STRAPPED LEG
UP TO 6.00'	3.00'
6.01' TO 8.00'	4.00'
8.01' TO 10.00'	5.00'
10.01' TO 12.00'	6.00'
OVER 12.01'	7.00'

NOT TO SCALE