



NOTES:

1. THE ODOR CONTROL SYSTEM SHALL INCLUDE A 1,000 GALLON CHEMICAL TANK AND A CHEMICAL FEED METERING PUMP (APPROVED METERING PUMP).
2. THE CHEMICAL TANK SHALL BE FILLED WITH CALCIUM NITRATE TETRAHYDRATE OR CHEMICAL SPECIFIED BY THE DIRECTOR OF WATER RESOURCES PRIOR TO OPERATION.
3. ODOR CONTROL SYSTEM SHALL BE PIPED TO JUST BELOW THE WET WELL HATCH.
4. TIMER IS REQUIRED AS APPROVED BY THE DIRECTOR OF WATER RESOURCES.
5. TANK AND SLAB SHALL BE DESIGNED IN ACCORDANCE WITH APPLICABLE FEDERAL OR STATE SECONDARY CONTAINMENT STANDARDS.
6. SLAB SHALL BE DESIGNED FOR THE PROPOSED TANK DIMENSIONS AND WEIGHT AND FOR THE SITE SPECIFIC SOIL CONDITIONS.
7. THE ODOR CONTROL BUILDING AND SYSTEM SHALL BE DESIGNED IN ACCORDANCE WITH OSHA REQUIREMENTS.
8. SCADA SENSORS ARE REQUIRED TO INCLUDE, BUT NOT LIMITED TO, PUMP SETTINGS, EYEWASH/SHOWER ACTIVATION, SPILL ALARM, TANK LEVEL TRANSMITTER, AND INTRUSION ALARM ON DOOR.

NOT TO SCALE